• Part Number: 1926

• Part Title: Safety and Health Regulations for Construction

• Subpart: K

Subpart Title: ElectricalStandard Number: 1926.431

• Title: Maintenance of equipment.

• GPO Source: <u>e-CFR</u>

The employer shall ensure that all wiring components and utilization equipment in hazardous locations are maintained in a dust-tight, dust-ignition-proof, or explosion-proof condition, as appropriate. There shall be no loose or missing screws, gaskets, threaded connections, seals, or other impairments to a tight condition.